

SIZING AND SELECTION TSS-A COOLING TOWER PUMP FLOW RATE (FOR HIGH HEAD "HH" ONLY) 15% SIDE STREAM FILTRATION REQUIRED

- **TSS-A:** Used when a full flow SBC has been installed on the cooling tower condenser line. Separator with automatic purge to waste with a MBVSR (Motorized Ball Valve with Spring Return), solid waste recovery through stainless steel tank, (optional NRT = No Recovery Tank), control panel, service light, pump/motor, basket strainer, corrosion coupon rack, and conductivity controller.
 - System Requirement: Full flow SBC Reaction Chamber and Driver. (Purchased separately).

- **HH:** High Head pump. Flooded suction required.
SIDE STREAM FILTRATION TO COOLING TOWER BASIN WITH SWEEPER PIPING.
Any Basin designed to function without Sweeper Piping allows a Low Head Pump selection.

1. **When you have the cooling tower GPM only (the tonnage, the model number, or the basin size are not available).**
 Example ~ A GPM of 2800 at 15% side stream equals 420 calculated GPM.

Selection is based on the GPM of the system that is closest to the calculated GPM, or the customer's tolerance for any extra horsepower in yearly consumption. The cost of the system may become a factor when you decide whether or not to purchase the next larger sized package. Example ~ Series 401 (420 GPM)

2. **When you have the tonnage only (the model number, the basin size, or the cooling tower flow rate are not available).**
 Example ~ 200 ton x 3* = 600 calculated GPM; 600 calculated GPM at 15 % side stream equals 90 GPM.

* 3 GPM/ton is based upon the nominal open loop tower conditions of 95/85/78 degrees F.

Selection is based on the GPM of the system that is closest to the calculated GPM, or the customer's tolerance for any extra horsepower in yearly consumption. The cost of the system may become a factor when you decide whether or not to purchase the next larger sized package: Example ~ Series 200 (90 GPM)

3. **When you have the model number only (the cooling tower GPM, the tonnage, or the basin size are not available).**
 Refer to the manufacturer's literature to obtain the GPM.

Example ~ Select nominal temperature. Hot water is 95°F; cold water 85°F; and wet bulb is 78°F. A GPM of 1017 for Marley Model # NC8304F 95/85/78 cooling tower at 15% side stream equals 152.5 calculated GPM.

Selection is based on the GPM of the system that is closest to the calculated GPM, or the customer's tolerance for any extra horsepower in yearly consumption. The cost of the system may become a factor when you decide whether or not to purchase the next larger sized package: Example ~ Series 251 (160 GPM)

4. **As a last resort, when only the basin size is available:**

Calculate the dimensions (Length x Width) of the basin to determine the gpm. Example ~ 9ft. x 17ft. = 153 calculated gpm. Selection is based on the gpm of the system that is closest to the calculated gpm, or the customer's tolerance for any extra horsepower in yearly consumption. The cost of the system may become a factor when you decide whether or not to purchase the next larger sized package. Example ~ Series 250 (130 gpm) or Series 251 (160 gpm).

SEPARATOR SYSTEMS SELECTION CHART				
SEPARATOR SIZE	NOMINAL FLOW		HIGHER FLOW	
	SERIES	FLOW (GPM)	SERIES	FLOW (GPM)
1"	100-HH	23	101-HH	28
1-1/4"	120-HH	40	121-HH	50
1-1/2"	150-HH	54	151-HH	68
2"	200-HH	90	201-HH	115
2-1/2"	250-HH	130	251-HH	160
3"	300-HH	200	301-HH	250
4"	400-HH	340	401-HH	420
5"	500-HH	510	501-HH	650
6"	600-HH	810	601-HH	1100
8"	800-HH	1400	801-HH	1700
10"	1000-HH	2000	1001-HH	2700
12"	1200-HH	2900	1201-HH	3700

NOTE: Consult factory for assistance if number of educators or nozzles are specified.